

ADDENDUM NO. 2

DATE: October 28, 2016
PROJECT NAME: Gallup Skatepark
FORMAL BID NO.: 1624

TO: ALL BIDDERS OF RECORD

This Addendum forms a part of the contract Documents and modifies or supplements the Project Manual or the Drawings as indicated below. All other provisions of the Contract Documents shall remain unchanged. This Addendum is hereby made a part of the Contract Documents to the same extent as those provisions contained in the original documents and all itemized listings thereof. Bidders shall acknowledge receipt of this Addendum in the appropriate space on PAGE 19 of the Contract Manual.

I. CONTRACT MANUAL

1. ADVERTISEMENT FOR BID AND GENERAL CONDITIONS PAGE 1: The bid submittal date shall be changed to November 8, 2016 at 2:00 local time. The location where the bids will be accepted shall remain the same.
2. BID PROPOSAL FORM: Delete the Bid Proposal Form (pages 20 through 23) in its entirety and replace with the attached Bid Proposal Form.
 - a. The format shall be corrected to fix spacing errors in the Estimated Quantities for Items 5 and 11.
 - b. The description of Item 54 Mobilization shall be changed to remove the 5% limit, as shown in the amended form. The contractor shall be limited to billing 25% of the total line item amount for Mobilization per each of the first four monthly invoices.

II. PLANS

1. DEMOLITION PLAN SHEET LD101: Delete Sheet LD101 in its entirety and replace with the attached Sheet LD101. The plan is revised to show existing spot elevations and revised limits of asphalt removal (page 7 of 10).
2. CONSTRUCTION PLAN SHEET LS101: Delete Sheet LS101 in its entirety and replace with the attached Sheet LS101 (page 8 of 10).
 - a. The plan is revised to show spot elevations on the curb and other site features.
 - b. Construction Keyed Note #12. Add to the description “The existing storm drain line is concrete with an approximate inside diameter of 4’7”. Invert elevations are shown on the Demolition Plan Sheet LD101. A manhole is not required at the point of connection to the storm drain line.”
 - c. Construction Note B. Add to the note “Locally sourced tan or gold gravel is an acceptable substitution to ‘Canyon Gold’.”

3. CALL OUT PLAN SHEET SK-2: Keyed note #35. The model specification number shall be changed to “111640B Recycled Contour Series Bench 60” without back and without armrests, 2” SM.”

III. BIDDERS' QUESTIONS & CLARIFICATIONS TO BIDDERS

1. QUESTION: Are subcontractors required to hold a valid New Mexico contractor's license?
ANSWER: Yes, any work subcontracted by a prime contractor must be performed by an entity that is validly licensed in New Mexico in the classification(s) of the work that is to be subcontracted.

2. QUESTION: Is the engineers estimate available?
ANSWER: Yes, the engineers estimate is attached to this addendum (pages 9 and 10 of 10).

END OF ADDENDUM NO. 2

Morrow Reardon Wilkinson Miller, Ltd.

City of Gallup



By _____

By _____

**BID PROPOSAL FORM
FORMAL BID NO. 1624**

THE BIDDER AGREES TO PERFORM ALL THE WORK AS DESCRIBED IN THE GENERAL CONDITIONS AND PLANS TO PROVIDE GALLUP SKATEPARK FOR THE FOLLOWING SUM:

Base Bid - Unit Prices

Bid Item #	Item Description	Est. Qty	Unit	Unit Price	Amount
1	Furnish, install, and maintain project construction fencing, complete in place.	1	LS		
2	Remove and dispose of existing concrete curb, complete.	564	LF		
3	Remove and dispose of existing concrete slab, complete.	1	LS		
4	Remove and dispose of existing concrete curb and gutter, complete.	87	LF		
5	Remove and dispose of existing asphalt paving, including sawcut edge, complete.	19,736	SF		
6	Remove and dispose of existing tree, including stump grinding, complete.	3	EA		
7	Remove and dispose of shrub, complete.	8	EA		
8	Remove and dispose of light pole, including footing and disconnection of electrical supply, complete.	2	EA		
9	Remove and dispose of railroad track, complete.	1	LS		
10	Remove and dispose drain inlet, including capping drain line, complete.	1	LS		
11	Remove and dispose of gravel, complete.	29,909	SF		
12	Grading, including rough grading and fine grading, complete	1	LS		

Bid Item #	Item Description	Est. Qty	Unit	Unit Price	Amount
13	4" thick concrete sidewalk pavement, complete in place.	714	SF		
14	Concrete header curb, complete in place.	345	LF		
15	3" gravel mulch, complete in place	9,914	SF		
16	Concrete mountable curb, complete in place.	48	LF		
17	Parking lot striping including white stall lines, ADA parking stall lines, and ADA symbols, complete in place.	1	LS		
18	4" drain line including connection to existing storm drain line, complete in place	222	LF		
19	12" area drain, complete in place.	2	EA		
20	Skatepark concrete paving, complete in place.	9,015	SF		
21	Skatepark perimeter footing, complete in place.	938	LF		
22	Skatepark concrete transition ramp including steel coping, complete in place.	1	LS		
23	Skatepark concrete flat ramp, complete in place.	1,410	SF		
24	Skatepark concrete eight stair, complete in place.	1	LS		
25	Skatepark concrete sloped ledge at double set including steel edge, complete in place.	1	LS		
26	Skatepark concrete bench including steel edge, complete in place.	1	LS		
27	Skatepark flat rail, complete in place.	1	LS		
28	Skatepark concrete turn down edge including steel edge, complete in place.	26	LF		
29	Skatepark concrete retaining wall, complete in place.	66.5	LF		
30	Skatepark pole jam, complete in place.	1	LS		

Bid Item #	Item Description	Est. Qty	Unit	Unit Price	Amount
31	Skatepark rail at 8 stair including steel edge, complete in place.	1	LS		
32	Skatepark hubba at 8 stair including steel edge, complete in place.	1	LS		
33	Skatepark double set (steps) including steel edge, complete in place.	1	LS		
34	Skatepark step up bank including steel edge, complete in place.	1	LS		
35	Skatepark rail/curb at double set, complete in place.	1	LS		
36	Skatepark two stair including steel edge, complete in place.	1	LS		
37	Skatepark outtrail including concrete curb, complete in place.	1	LS		
38	Skatepark slappy hubba including steel edge, complete in place.	1	LS		
39	Skatepark volcano ramp including embedded boulder and steel coping, complete in place.	1	LS		
40	Skatepark floating ¼ pipe including steel edge, complete in place.	1	LS		
41	Skatepark bench and bank w/ curb including steel edge, complete in place.	1	LS		
42	Skatepark flat down rail, complete in place.	1	LS		
43	Skatepark guard rail, complete in place.	66.5	LF		
44	Skatepark A-frame gap, complete in place.	1	LS		
45	Skatepark A-frame ledge including steel edge, complete in place.	1	LS		
46	Skatepark A-frame rail, complete in place.	1	LS		
47	Skatepark Belmont ledge including steel edge, complete in place.	1	LS		
48	Skatepark curb at perimeter ftg., complete in place.	91	LF		
49	Skatepark landscape boulder, complete in place.	27	EA		

Bid Item #	Item Description	Est. Qty	Unit	Unit Price	Amount
50	Skatepark bench, complete in place.	2	EA		
51	Skatepark big blocks/boulder including steel edge and embedded boulder, complete in place.	1	LS		
52	Skatepark target symbol, complete in place.	1	LS		
53	Surveying	1	LS		
54	Mobilization	1	LS		

- a) **Base Bid** – Subtotal of Bid Items No. 1 through 54 \$ _____
- b) **Allowances:**
Materials Lab Testing \$ 8,000.00
Total Allowances: \$ 8,000.00
- c) **Subtotal** – Line a) Base Bid subtotal plus Line b) Allowances: \$ _____
- d) **New Mexico Gross Receipts Tax (NMGRT)**
on amount on Line c) Subtotal at 8.3125%: \$ _____
- e) **BASE BID TOTAL** – Line c) Subtotal plus Line d) NMGRT: \$ _____

_____ Dollars
(Base Bid Total amount written in words)

IN THE CASE OF A DISCREPANCY, THE AMOUNTS SHOWN IN WORDS SHALL GOVERN.

SUBMITTED BY: Business Name _____

SIGNED By: _____

Authorized Signature	Name Printed or Typed
_____	_____
Title	Date
_____	_____
Address	Phone & Fax Number
_____	_____
City, State, Zip	Email Address
_____	_____
D.W.S. Registration No.	N.M. Contractor's License No.
_____	_____

DEMOLITION KEYED NOTES

1. EXISTING ASPHALT TO REMAIN.
2. EXISTING CURB TO REMAIN.
3. EXISTING CURB TO BE REMOVED AND PROPERLY DISPOSED OF.
4. EXISTING CONCRETE SLAB TO BE REMOVED AND PROPERLY DISPOSED OF.
5. EXISTING CURB AND GUTTER TO BE REMOVED AND PROPERLY DISPOSED OF.
6. EXISTING ASPHALT TO BE REMOVED AND PROPERLY DISPOSED OF.
7. SAW CUT ASPHALT WITH A CLEAN STRAIGHT LINE.
8. EXISTING SHRUB TO REMAIN.
9. EXISTING CURB AND GUTTER TO REMAIN.
10. EXISTING TREE TO REMAIN.
11. EXISTING TREE TO BE REMOVED AND PROPERLY DISPOSED OF. GRIND STUMP 18" BELOW FINISH GRADE AND FILL VOID WITH CLEAN FILL DIRT.
12. EXISTING SHRUB TO BE REMOVED AND PROPERLY DISPOSED OF.
13. EXISTING 6' HT CHAINLINK FENCE TO REMAIN.
14. EXISTING LIGHT POLE AND FOOTING TO BE REMOVED AND PROPERLY DISPOSED OF. VOID SHALL BE FILLED WITH CLEAN FILL DIRT. DISCONNECT ELECTRICAL SUPPLY AND TERMINATE TO MEET ALL APPLICABLE CODES.
15. EXISTING SIGN TO REMAIN.
16. RAILROAD TRACKS TO BE REMOVED AND PROPERLY DISPOSED OF.
17. EXISTING STORM DRAIN LINE TO REMAIN.
18. EXISTING DROP INLET TO BE REMOVED AND PROPERLY DISPOSED OF. CAP LINE 1' BELOW GRADE.
19. EXISTING GRAVEL TO BE REMOVED AND PROPERLY DISPOSED OF.
20. SOIL TO BE REMOVED AND STOCKPILED FOR REUSE ON SITE.

DEMOLITION GENERAL NOTES

- A. EXISTING IRRIGATION WHERE TREES AND SHRUBS ARE REMOVED SHALL BE CAPPED 6" BELOW FINISH GRADE.
- B. CONTRACTOR SHALL FILL AND COMPACT ALL VOIDS CREATED BY DEMOLITION WORK WITH CLEAN BACKFILL MATERIAL WHICH SHALL BE APPROVED BY OWNER PRIOR TO BACKFILL OPERATIONS.
- C. CONTRACTOR SHALL PROTECT EXISTING UTILITIES FROM DAMAGE. ANY DAMAGE TO EXISTING UTILITIES SHALL BE REPAIRED BY THE CONTRACTOR AT NO ADDITIONAL COST TO THE OWNER.
- D. TWO WORKING DAYS PRIOR TO ANY EXCAVATION, THE CONTRACTOR SHALL CONTACT NEW MEXICO ONE CALL SYSTEM (1-800-321-2537) FOR LOCATION OF EXISTING UTILITIES.
- E. CONTRACTOR SHALL TAKE ALL NECESSARY PRECAUTIONS TO ENSURE NO DAMAGE OCCURS TO EXISTING STRUCTURES, TREES, AND PAVEMENT TO REMAIN AND ITEMS TO BE SALVAGED. ANY DAMAGE TO ITEMS TO REMAIN OR TO BE SALVAGED RESULTING FROM CONSTRUCTION OPERATIONS SHALL BE REPAIRED AND/OR REPLACED AT NO ADDITIONAL COST TO THE OWNER.
- F. ALL AREAS ADJACENT TO THE SITE SHALL BE MAINTAINED IN A CLEAN CONDITION, MUD AND DUST FREE AT ALL TIMES.
- G. PRIOR TO START OF CONSTRUCTION, CONTRACTOR SHALL COORDINATE WITH THE OWNER TO CONDUCT A PRE-CONSTRUCTION PERFORMANCE REVIEW OF THE ENTIRE EXISTING PARKING LOT IRRIGATION SYSTEM TO ENSURE EXISTING IRRIGATION SYSTEM IS IN PROPER WORKING ORDER. EACH CONTROL VALVE SHALL BE ACTIVATED FROM THE CONTROLLER. THE OPERATION OF EACH VALVE SHALL BE REVIEWED. AFTER COMPLETION OF CONSTRUCTION, CONTRACTOR SHALL COORDINATE WITH THE OWNER TO CONDUCT A POST-CONSTRUCTION PERFORMANCE REVIEW OF THE EXISTING IRRIGATION SYSTEM. EACH CONTROL VALVE SHALL BE ACTIVATED FROM THE CONTROLLER. THE OPERATION OF EACH VALVE SHALL BE REVIEWED. CONTRACTOR SHALL BE RESPONSIBLE FOR REPAIR OR REPLACEMENT OF ANY DEFICIENCIES NOT IDENTIFIED AT THE PRE-CONSTRUCTION PERFORMANCE REVIEW. CONTRACTOR SHALL PROVIDE WRITTEN DOCUMENTATION OF RESULTS OF PRE-CONSTRUCTION AND POST CONSTRUCTION REVIEWS TO THE OWNER.
- H. AT LOCATIONS WHERE EXISTING PLANTS AND LANDSCAPE AREAS ARE BEING REMOVED THE CONTRACTOR SHALL LOCATE AND UNCOVER EXISTING DRIP IRRIGATION TUBING. EXISTING DRIP IRRIGATION TUBING SHALL BE CUT AND CAPPED AS DIRECTED BY LANDSCAPE ARCHITECT IN THE FIELD.
- I. CONTRACTOR SHALL MAINTAIN A CLEAN PROJECT SITE FOR THE ENTIRE DURATION OF THE WORK. CONTRACTOR SHALL REMOVE ANY DIRT OR DEBRIS FROM TRUCKS LEAVING THE SITE OR BE RESPONSIBLE FOR CLEANING ANY DIRT TRACKED OFF SITE.
- J. CONTRACTOR SHALL BE RESPONSIBLE FOR SECURING THE PROJECT SITE FOR THE ENTIRE DURATION OF THE WORK.

HATCH AND SYMBOL LEGEND


- EXISTING ASPHALT PAVING TO BE REMOVED - SEE KEYED NOTE 6.
- EXISTING GRAVEL TO BE REMOVED - SEE KEYED NOTE 19.
- EXISTING DECIDUOUS TREE TO REMAIN.
- EXISTING PINE TREE TO REMAIN.
- EXISTING PINE TREE TO BE REMOVED.
- EXISTING SHRUB TO REMAIN.
- EXISTING TREE TO BE REMOVED.
- EXISTING SHRUB TO BE REMOVED.

GRADING LEGEND

8.36 SPOT ELEVATION

GRADING ABBREVIATIONS


- EX EXISTING ELEVATION
- BC BOTTOM OF CURB
- TOA TOP OF ASPHALT
- TOC TOP OF CURB
- TG TOP OF EXIST GRATE AT DROP INLET
- FG FINISH GRADE



A1 DEMOLITION PLAN
 SCALE: 1"=20'-0"



CONSULTANTS



**GALLUP SKATE PARK
 GALLUP, NM**

OCTOBER 1, 2016

SUBMITTAL: FINAL FOR CONSTRUCTION

REVISIONS

NO.	DATE	DESCRIPTION
1	10/28/16	ADDENDUM 2

PROJECT NO: 7214
 CAD DWG FILE:
 DESIGNED BY: GAM DATE: 10/1/16
 DRAWN BY: JSP DATE: 10/1/16
 CHECKED BY: GAM DATE: 10/1/16
SHEET TITLE

**DEMOLITION
 PLAN**

DRAWING SHEET
LD101

CONSULTANTS



GALLUP SKATE PARK
 GALLUP, NM

OCTOBER 1, 2016

SUBMITTAL: FINAL FOR CONSTRUCTION


REVISIONS

NO.	DATE	DESCRIPTION
1	10/28/16	ADDENDUM 2

PROJECT NO: 7214
 CAD DWG FILE:
 DESIGNED BY: GAM DATE: 10/1/16
 DRAWN BY: JSP DATE: 10/1/16
 CHECKED BY: GAM DATE: 10/1/16
 SHEET TITLE

SITE
 CONSTRUCTION
 PLAN

DRAWING SHEET
 LS101




KEYED NOTES

- 3000 PSI CONCRETE PAVING W/MEDIUM BROOM FINISH.
- EXPANSION JOINT PER PLAN. SEE GENERAL NOTE #B.
- CONTROL JOINT PER PLAN. SEE GENERAL NOTE #C.
- 95% COMPACTED SUBGRADE.

GENERAL NOTES

- A. CONTROL JOINTS AND EXPANSION JOINTS SHALL BE AS SHOWN ON PLAN. INSTALL EXPANSION JOINTS WHERE PAVING ABUTS EXISTING BUILDINGS, CURBS, SEATING WALLS, WALKS AND OTHER HARD CONSTRUCTION.
- B. 1/2" WIDE EXPANSION JOINT WITH FELT EXPANSION MATERIAL. FELT EXPANSION MATERIAL SHALL BE RECESSED 1/2" OPPOSING CONCRETE EDGES OF JOINT SHALL HAVE 1/4" RADIUS TOOLED EDGE. JOINTS SHALL BE LOCATED EVERY 30'-0" O.C. MAXIMUM. FELT EXPANSION MATERIAL SHALL BE SET WITH PLASTIC EXPANSION JOINT CAP. TOP OF CAP SHALL BE FLUSH WITH TOP OF CONCRETE. AFTER CONCRETE HAS CURED, TOP OF CAP SHALL BE REMOVED AND DISCARDED. RESULTING CHANNEL SHALL BE FILLED WITH ONE-PART ELASTOMERIC SELF-LEVELING POLYURETHANE SEALANT. TOP OF SEALANT SHALL BE FLUSH WITH (OR SLIGHTLY BELOW) TOP OF CONCRETE. FINISHED SEALANT SHALL HAVE A SMOOTH STRAIGHT UNIFORM EDGE AND SHALL NOT EXTEND OVER SURFACE OF CONCRETE OR INTO ADJACENT CONTROL JOINTS. SEALANT SHALL BE APPLIED PER MANUFACTURER'S RECOMMENDATIONS. CONTRACTOR SHALL PROTECT JOINT FROM DIRT AND TRAFFIC UNTIL SEALANT HAS CURED. CONTRACTOR SHALL SUBMIT SEALANT COLOR SAMPLES TO LANDSCAPE ARCHITECT FOR SELECTION PRIOR TO APPLICATION.
- C. 1/8" X 1" DEEP TOOLED AND SAW CUT CONTROL JOINT. JOINTS SHALL BE TOOLED FIRST, THEN SAW CUT TO 1" DEPTH. THE SAW CUT JOINTS SHALL BE CUT WITHIN 1-4 HOURS (DEPENDING UPON WEATHER CONDITIONS) AFTER FINISHING OF CONCRETE. JOINTS SHALL BE CUT WITH AN EARLY ENTRY TYPE DRY CUT SAW. SPALLING OF CONCRETE FINISH AT EDGE OF CUT IS NOT ACCEPTABLE.

B4 CONCRETE SIDEWALK PAVING
 SCALE: 1 1/2" = 1'-0"



CONSTRUCTION KEYED NOTES

- 4" THICK CONCRETE SIDEWALK PAVEMENT PER DETAIL B4/LS101.
- SKATE PARK - SEE ALL SK SHEETS.
- NEW CURB AND GUTTER SHALL CONNECT TO EXISTING HEADER CURB.
- 3" OF GRAVEL MULCH. SEE CONSTRUCTION NOTE B.
- EXISTING ASPHALT TO REMAIN.
- EXISTING CURB AND GUTTER TO REMAIN.
- EXISTING HEADER CURB TO REMAIN.
- CONCRETE MOUNTABLE CURB PER DETAIL C2/LS501.
- ADA PARKING STALL AND ACCESS AISLE PER DETAIL C4/LS501 AND B2/LS501.
- TWO COATS OF WHITE TRAFFIC PAINT, 6" WIDE X 20' LONG.
- CONCRETE CURB AT ASPHALT EDGE PER DETAIL C1/LS101.
- 4" DRAIN LINE. TIE INTO EXISTING STORM DRAIN LINE PER NMDOT APPROVED METHOD. CONTRACTOR SHALL OBTAIN WRITTEN AUTHORIZATION FROM NMDOT PRIOR TO CONNECTION. SLOPE TO DRAIN, CONFIRM GRADES WITH LANDSCAPE ARCHITECT PRIOR TO INSTALLATION.
- THE EXISTING STORM DRAIN LINE IS CONCRETE WITH AN APPROXIMATE INSIDE DIAMETER OF 4' 7". INVERT ELEVATIONS ARE SHOWN ON THE DEMOLITION PLAN SHEET LD101. A MANHOLE IS NOT REQUIRED AT THE POINT OF CONNECTION TO THE STORM DRAIN.
- 12" AREA DRAIN AT LANDSCAPE AREA PER DETAIL A1/LS501.
- SKATE PARK - SEE ALL SK SHEETS.

CONSTRUCTION NOTES

- A. CONTRACTOR SHALL PERFORM A GEOTECHNICAL SOIL TEST TO DETERMINE PROCTOR AND BEARING CAPACITY OF EXISTING SOIL. TESTING SHALL BE PERFORMED AFTER ASPHALT REMOVAL AND BEFORE CONCRETE CONSTRUCTION. CONTRACTOR SHALL PROVIDE TESTING RESULTS TO LANDSCAPE ARCHITECT PRIOR TO CONCRETE CONSTRUCTION.
- B. GRAVEL MULCH SHALL BE 1" "CANYON GOLD", AS AVAILABLE FROM BUILDIOLOGY, INC. (505-333-0335), OR APPROVED EQUAL, INSTALLED AT A 3" DEPTH OVER FILTER FABRIC. (LOCALLY SOURCED TAN OR GOLD GRAVEL IS AN ACCEPTABLE SUBSTITUTION TO "CANYON GOLD".)
- C. FILTER FABRIC SHALL BE MIN. 4 OZ. NON-WOVEN NEEDLE-PUNCHED POLYPROPYLENE (MIRAFI OR EQUIVALENT). OVERLAP ENDS 3" AND TURN DOWN EDGES 6".
- D. THE TOP OF MULCH SHALL BE 1" BELOW TOP OF ADJACENT CONCRETE SURFACES.

HATCH LEGEND


- 4" THICK CONCRETE PAVEMENT - SEE KEYED NOTE 1.
- GRAVEL MULCH - SEE CONSTRUCTION NOTE B.

GRADING LEGEND

SPOT ELEVATION

GRADING ABBREVIATIONS



- EX EXISTING ELEVATION
- TOA TOP OF ASPHALT
- TOC TOP OF CURB



GENERAL NOTES

- PLACE EXPANSION JOINTS AT 13'-0" O.C. WITH CONTROL JOINTS AT 5'-0" O.C.

C1 6" BY 12" CONCRETE HEADER CURB
 3" = 1"



A1 SITE CONSTRUCTION PLAN
 SCALE: 1" = 20'-0"



Gallup Skatepark - Opinion of Probable Cost 10/27/2016

<u>Bid</u> <u>Item</u>	<u>ITEM DESCRIPTION</u>	<u>Est.</u> <u>Quantity</u>	<u>Unit</u>	<u>UNIT PRICE</u>	<u>EXTENDED PRICE</u>
1	Furnish, install, and maintain project construction fencing, complete in place.	1	LS	\$ 500.00	\$ 500.00
2	Remove and dispose of existing concrete curb, complete.	564	LF	\$ 12.00	\$ 6,768.00
3	Remove and dispose of existing concrete slab, complete.	1	LS	\$ 500.00	\$ 500.00
4	Remove and dispose of existing concrete curb and gutter, complete.	87	LF	\$ 15.00	\$ 1,305.00
5	Remove and dispose of existing asphalt paving, including sawcut edge, complete.	19736	SF	\$ 0.85	\$ 16,775.60
6	Remove and dispose of existing tree, including stump grinding, complete.	3	EA	\$ 500.00	\$ 1,500.00
7	Remove and dispose of shrub, complete.	8	EA	\$ 15.00	\$ 120.00
8	Remove and dispose of light pole, including footing and disconnection of electrical supply, complete.	2	EA	\$ 500.00	\$ 1,000.00
9	Remove and dispose of railroad track, complete.	1	LS	\$ 500.00	\$ 500.00
10	Remove and dispose drain inlet, including capping drain line, complete.	1	LS	\$ 1,000.00	\$ 1,000.00
11	Remove and dispose of gravel, complete.	29909	SF	\$ 0.25	\$ 7,477.25
12	Grading, including rough grading and fine grading, complete	1	LS	\$ 15,000.00	\$ 15,000.00
13	4" thick concrete sidewalk pavement, complete in place.	714	SF	\$ 5.50	\$ 3,927.00
14	Concrete header curb, complete in place.	345	LF	\$ 15.00	\$ 5,175.00
15	3" gravel mulch, complete in place	9914	SF	\$ 1.50	\$ 14,871.00
16	Concrete mountable curb, complete in place.	48	LF	\$ 25.00	\$ 1,200.00
17	Parking lot striping including white stall lines, ADA parking stall lines, and ADA symbols, complete in place.	1	LS	\$ 2,500.00	\$ 2,500.00
18	4" drain line including connection to existing storm drain line, complete in place	222	LF	\$ 25.00	\$ 5,550.00
19	12" area drain, complete in place.	2	EA	\$ 500.00	\$ 1,000.00
20	Skatepark concrete paving, complete in place.	9015	SF	\$ 7.00	\$ 63,105.00
21	Skatepark perimeter footing, complete in place.	938	LF	\$ 25.00	\$ 23,450.00
22	Skatepark concrete transition ramp including steel coping, complete in place.	1	LS	\$ 20,000.00	\$ 20,000.00
23	Skatepark concrete flat ramp, complete in place.	1410	SF	\$ 10.00	\$ 14,100.00
24	Skatepark concrete eight stair, complete in place.	1	LS	\$ 3,500.00	\$ 3,500.00
25	Skatepark concrete sloped ledge at double set including steel edge, complete in place.	1	LS	\$ 2,000.00	\$ 2,000.00
26	Skatepark concrete bench including steel edge, complete in place.	1	LS	\$ 3,500.00	\$ 3,500.00
27	Skatepark flat rail, complete in place.	1	LS	\$ 750.00	\$ 750.00
28	Skatepark concrete turn down edge including steel edge, complete in place.	26	LF	\$ 65.00	\$ 1,690.00
29	Skatepark concrete retaining wall, complete in place.	66.5	LF	\$ 120.00	\$ 7,980.00
30	Skatepark pole jam, complete in place.	1	LS	\$ 750.00	\$ 750.00

Gallup Skatepark - Opinion of Probable Cost 10/27/2016

<u>Bid Item</u>	<u>ITEM DESCRIPTION</u>	<u>Est. Quantity</u>	<u>Unit</u>	<u>UNIT PRICE</u>	<u>EXTENDED PRICE</u>
31	Skatepark rail at 8 stair including steel edge, complete in place.	1	LS	\$ 1,000.00	\$ 1,000.00
32	Skatepark hubba at 8 stair including steel edge, complete in place.	1	LS	\$ 3,000.00	\$ 3,000.00
33	Skatepark double set (steps) including steel edge, complete in place.	1	LS	\$ 6,000.00	\$ 6,000.00
34	Skatepark step up bank including steel edge, complete in place.	1	LS	\$ 2,500.00	\$ 2,500.00
35	Skatepark rail/curb at double set, complete in place.	1	LS	\$ 1,000.00	\$ 1,000.00
36	Skatepark two stair including steel edge, complete in place.	1	LS	\$ 1,250.00	\$ 1,250.00
37	Skatepark outrail including concrete curb, complete in place.	1	LS	\$ 1,500.00	\$ 1,500.00
38	Skatepark slappy hubba including steel edge, complete in place.	1	LS	\$ 3,000.00	\$ 3,000.00
39	Skatepark volcano ramp including embedded boulder and steel coping, complete in place.	1	LS	\$ 7,500.00	\$ 7,500.00
40	Skatepark floating ¼ pipe including steel edge, complete in place.	1	LS	\$ 5,000.00	\$ 5,000.00
41	Skatepark bench and bank w/ curb including steel edge, complete in place.	1	LS	\$ 2,000.00	\$ 2,000.00
42	Skatepark flat down rail, complete in place.	1	LS	\$ 1,000.00	\$ 1,000.00
43	Skatepark guard rail, complete in place.	66.5	LF	\$ 75.00	\$ 4,987.50
44	Skatepark A-frame gap, complete in place.	1	LS	\$ 7,500.00	\$ 7,500.00
45	Skatepark A-frame ledge including steel edge, complete in place.	1	LS	\$ 5,000.00	\$ 5,000.00
46	Skatepark A-frame rail, complete in place.	1	LS	\$ 1,000.00	\$ 1,000.00
47	Skatepark Belmont ledge including steel edge, complete in place.	1	LS	\$ 10,000.00	\$ 10,000.00
48	Skatepark curb at perimeter ftg., complete in place.	91	LF	\$ 20.00	\$ 1,820.00
49	Skatepark landscape boulder, complete in place.	27	EA	\$ 250.00	\$ 6,750.00
50	Skatepark bench, complete in place.	2	EA	\$ 1,200.00	\$ 2,400.00
51	Skatepark big blocks/boulder including steel edge and embedded boulder, complete in place.	1	LS	\$ 5,000.00	\$ 5,000.00
52	Skatepark target symbol, complete in place.	1	LS	\$ 2,500.00	\$ 2,500.00
53	Surveying	1	LS	\$ 15,000.00	\$ 15,000.00
54	Mobilization	1	LS	\$ 35,000.00	\$ 35,000.00

	SUBTOTAL	\$ 359,201.35
Testing		\$ 8,000.00
	TOTAL	\$ 367,201.35
Tax	\$ 0.083125	\$ 30,523.61
		\$ 397,724.96